



**WASHINGTON STATE PARKS AND  
RECREATION COMMISSION  
ADDENDUM NO. ONE (1)**

**SCHAFER STATE PARK – RELOCATE CAMPGROUND  
SW-C1354**

**THIS DOCUMENT AND ATTACHMENT(S) ARE AVAILABLE FOR DOWNLOAD AT  
[http://www.bxwa.com/bxwa\\_toc/pub/1687/toc.html](http://www.bxwa.com/bxwa_toc/pub/1687/toc.html)  
AN EMAIL NOTIFICATION WAS SENT TO REGISTERED PLANHOLDERS. FAILURE TO  
ACKNOWLEDGE RECEIPT ON THE BID FORM DOES NOT AFFECT THE BIDDER'S  
OBLIGATION FOR COMPLIANCE.**

DATE: August 3, 2022

**ATTENTION TO PLANHOLDERS OF RECORD** is called to the following revisions of the contract documents:

**DRAWINGS:**

1. Sheet 73, Electrical Plan A – Revise secondary service feeding Main Electrical Pedestal from (2) 3”C – (4) #350 KCMIL (1) #2 GND to – (2) 4”C - (4) #350 KCMIL (1) #2 GND.
2. Sheet 75, Electrical Details, One Line Diagrams – Revise secondary service feeding Main Electrical Pedestal and Panel 4A from (2) 3”C – (4) #350 KCMIL (1) #2 GND to (2) 4”C - (4) #350 KCMIL (1) #2 GND.
3. Sheet 75, Electrical Details, One Line Diagrams – Revise Panel 4A MCB from 800A to 800A Frame\600A Trip.
4. Sheet 75, Electrical Details, Main Electrical Pedestal Detail – Revise Panel 4A MCB from 800A to 800A Frame\600A Trip.
5. Sheet 75, Electrical Details, Campsite Pedestal 2B/2C/2D Detail– Revise 2P 225A Enclosed circuit breaker to 2P 225A molded case switch.

**SPECIFICATIONS:**

1. Specification Section 265600 2.05A, Revise “bussed for 400 amps” to “bussed for 800 amps”.
2. Specification Section 265600 2.05C, Revise “120-208V three phase” to “120-240V single phase”.
3. Specification Section 265600 2.05D, Revise “120-208V three phase” to “120-240V single phase”.

Jacquie James  
Contracts Specialist 3

August 3, 2022  
Date